

**ADDENDUM NO. 1**

**To All Bidders of  
Township of Lower  
Lincoln Boulevard Storm Sewer Replacement  
(Beach Drive to Arctic Avenue)  
D&A Project #: LT-C-074**

You are hereby notified in accordance with ITB – Section 3.0 – Interpretation and Addenda of the above captioned project that the following has been issued to clarify the meaning of the plans and specifications and that the conditions and specifications set forth in said addenda are to be original contract documents.

**The following questions have been submitted, and the answers follow in bold and italics:**

- Q. The trench restoration detail for storm pipe on Sheet 6 of 8 consists of milling and 2 inches of HMA surface course. Is the contractor to include and install the proposed milling and surface course?
- A. ***Yes, for proposed trench restoration the contractor is to install 6" of DGA, then 8" of HMA base course at the end of each work week for a settling period of 60 days. After the 60 day settling period, the contractor shall mill at a depth of 2" and pave 2" of HMA surface course. Milling and paving limits shall not exceed a 1 foot width beyond trench excavation limits.***

**Please be advised of the following:**

- 1. The date of the bid opening has been changed from Tuesday, August 11, 2026 to Thursday, August 13, 2026 at 10:00 AM at Township of Lower Municipal Building, 2600 Bayshore Road, Villas, Cape May County, New Jersey.**
- 2. Remove Proposal Section PS-28 and replace with PS-28 (REVISED). Pay Items #18 and #19 have been added to the revised bid form with corresponding plan quantities.**
- 3. See revised plan set, please note the following plan sheets (Sheet Nos. 2-5) have been revised to include Pay Items #18 and #19.**
- 4. Remove Technical Specification Section 321216-1 and replace with Technical Specification 321216-1 (REVISED).**
- 5. Technical Specification 312299 "HMA Milling" has been included as supplemental information and shall be associated with Pay Item #18.**

**THIS ADDENDUM MUST BE RETURNED WITH ALL BIDS. THE FAILURE TO RETURN THIS SIGNED RECEIPT WITH THE CONTRACT FORMS WILL RESULT IN A NON-RESPONSIVE BID**

**I acknowledge receipt of this addendum.**

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company